



EC - DECLARATION OF CONFORMITY

NUMBER:1121 – CPD – AD0053

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993 We declare that the construction product:

construction product: **FAB EV300 Overhead Door Closer**

Placed on the market by: **ASSA ABLOY CZECH & SLOVAKIA, Dolnomecholupska 1418/12, 102 00 Prague 10, Czech Republic.**

product classification:

3	8	5 2	1 *	1	3
---	---	--------	--------	---	---

intended use: **For use on fire / smoke compartmentation doors**

particular conditions applicable: **Mounted in regular, transom and parallel arm positions, with adjustable backcheck and latch.**


This document certifies that all the provisions concerning the attestation of conformity and product performance described in Annex ZA of the product standard

EN 1154:1996 + A1:2002

Were applied and the product fulfils all the prescribed requirements.

Notified Certification Body: **Warrington Certification Ltd – (EC Notified Body 1121)**

This certificate was first issued on 22/09/04. The product was subsequently audit tested to EN1154 on 17/01/2007 under WAPT approved testing conditions and criteria , and remains valid as long as the conditions laid down in the harmonised technical specification above, or the product design, or the manufacturing conditions in the factory, or the FPC itself are not modified significantly, or at the latest 17/01/2012.


Tim J. Martin-Wright
Shenfei Liyi SPCL, CE Consultant
14/09/2009.

References:

Mechanical test evidence: 138409, 138409/P
Factory references: J/007

Fire test evidence: 139131/A
Classification report: N/a

* The referenced reports detail the precise field of application for fire / smoke door use